

**§ 143-215.94SS. Tank systems for emergency power generators.**

This section applies only to a facility that utilizes an underground storage tank system to store fuel solely for use by emergency power generators. A primary operator that has satisfactorily completed the training required by G.S. 143-215.94QQ at a facility shall be deemed trained as the primary operator at another facility that has identical spill prevention, overfill prevention, release detection, corrosion protection, emergency response, and product compatibility requirements as the facility for which the primary operator has satisfactorily completed training. (2010-154, s. 2.)